

# PARTY EVENTS UNLIMITED

## PORTABLE APPLIANCE TEST CERTIFICATE 2009

ASSET ID	DESCRIPTION	TEST DATE	DUE DATE	VISUAL	BOND (mΩ)	INSULATION (MΩ)	OPERATION (kVA)	LEAKAGE (mA)	POLARITY	OVERALL STATUS
F5233	EXT	13/03/2009	Mar-10	Pass	0.083	>50	-	-	OK	Pass
F5234	LEAD	13/03/2009	Mar-10	Pass	0.048	>50	-	-	OK	Pass
F5235	LEAD	13/03/2009	Mar-10	Pass	-	>50	0	0	-	Pass
F5236	LEAD	13/03/2009	Mar-10	Pass	-	>50	0	0	-	Pass
F5237	TURNTABLE	13/03/2009	Mar-10	Pass	-	>50	0.023	0	-	Pass
F5238	TURNTABLE	13/03/2009	Mar-10	Pass	-	>50	0.023	0	-	Pass
F5239	MIXER	13/03/2009	Mar-10	Pass	-	>50	0.025	0	-	Pass
F5240	LEAD	13/03/2009	Mar-10	Pass	0.055	>50	-	-	OK	Pass
F5241	EXT	13/03/2009	Mar-10	Pass	0.098	>50	-	-	OK	Pass
F5242	AMP	13/03/2009	Mar-10	Pass	0.068	>50	0.026	0	-	Pass
F5243	RADIO MIKE	13/03/2009	Mar-10	Pass	-	>50	0.009	0	-	Pass
F5244	LEAD	13/03/2009	Mar-10	Pass	0.045	>50	-	-	OK	Pass
F5245	DMX 512	13/03/2009	Mar-10	Pass	0.075	>50	0.01	0	-	Pass
F5246	LEAD	13/03/2009	Mar-10	Pass	0.105	>50	-	-	OK	Pass
F5247	LEAD	13/03/2009	Mar-10	Pass	0.107	>50	-	-	OK	Pass
F5248	LEAD	13/03/2009	Mar-10	Pass	0.05	>50	-	-	OK	Pass
F5249	PUMA LIGHTS	13/03/2009	Mar-10	Pass	0.148	>50	0.034	0	-	Pass
F5250	PUMA LIGHTS	13/03/2009	Mar-10	Pass	0.136	>50	0.035	0	-	Pass
F5251	BUBBLE MACHINE	13/03/2009	Mar-10	Pass	0.096	>50	0.061	0	-	Pass
F5252	EXT	13/03/2009	Mar-10	Pass	0.128	>50	-	-	OK	Pass
F5253	EXT	13/03/2009	Mar-10	Pass	0.075	>50	-	-	OK	Pass
F5254	EXT	13/03/2009	Mar-10	Pass	0.067	>50	-	-	OK	Pass
F5255	EXT	13/03/2009	Mar-10	Pass	0.064	>50	-	-	OK	Pass
F5256	EXT	13/03/2009	Mar-10	Pass	0.109	>50	-	-	OK	Pass
F5257	EXT	13/03/2009	Mar-10	Pass	0.097	>50	-	-	OK	Pass
F5258	EXT	13/03/2009	Mar-10	Pass	0.098	>50	-	-	OK	Pass
F5259	EXT	13/03/2009	Mar-10	Pass	0.083	>50	-	-	OK	Pass
F5260	EXT	13/03/2009	Mar-10	Pass	0.056	>50	0	0	-	Pass

ASSET ID	DESCRIPTION	TEST DATE	DUE DATE	VISUAL	BOND (mΩ)	INSULATION (MΩ)	OPERATION (kVA)	LEAKAGE (mA)	POLARITY	OVERALL STATUS
F5261	EXT	13/03/2009	Mar-10	Pass	0.077	>50	-	-	OK	Pass
F5262	LEAD	13/03/2009	Mar-10	Pass	0.055	>50	-	-	OK	Pass
F5263	LEAD	13/03/2009	Mar-10	Pass	0.047	>50	-	-	OK	Pass
F5264	DYNAMO LIGHTS	13/03/2009	Mar-10	Pass	0.092	>50	0.022	0	-	Pass
F5265	DYNAMO LIGHTS	13/03/2009	Mar-10	Pass	0.06	>50	0.022	0	-	Pass
F5266	LAMP	13/03/2009	Mar-10	Pass	0.105	>50	0.016	0	-	Pass
F5267	LAMP	13/03/2009	Mar-10	Pass	0.077	>50	0.014	0	-	Pass
F5268	LAMP	13/03/2009	Mar-10	Pass	-	>50	0.016	0	-	Pass
F5269	SMOKE MACHINE	13/03/2009	Mar-10	Pass	0.165	>50	0.635	0	-	Pass Advisory
F5270	EXT	13/03/2009	Mar-10	Pass	0.245	>50	-	-	OK	Pass

Advisory note: Casing on smoke machine F5269 showing signs of wear, we recommend replacement in the near future